

# Confirmation

## LEED v4.1

On 16 March 2020, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

**V420+ V3**

supplied by

**VJ Technology Ltd.**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350, ISO 11890-2, ASTM D2369 testing standards in the latest versions (See test report no. 392-2020-00129401\_H\_EN\_07 and no. 392-2020-00129402\_XG\_EN\_07).

**The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of Option 1 of LEED v4.1 BETA (July 2019): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of the South Coast Air Quality Management District (SCAQMD) Rule 1168 (2017) regarding multipurpose construction adhesives having a VOC content below 70 g/L.

2 September 2021



Peter Alexander Skov  
Analytical Chemist, MSc. Eng. Chemistry



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*