

# Confirmation

## LEED

On 27 March 2017, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

**E410+, EC410+**

supplied by

**VJ Technology Ltd.**

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2017-00105902\_H\_EN\_23 and 392-2017-00106002\_XD\_EN\_23).

**The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:**


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of SCAQMD rule 1168 (2005)

19 June 2020



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.